



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka Undertaking)

No: EEE/HSRD/AEE(O)/AE-1/NOC-23/19-20/

Encl:

E-mail:eehsr@bescom.org

Gmail:eehsr.work@gmail.com

Ph / Fax: 08022584381



Office of the ,
Executive Engineer, (Ele.,)
C, O&M, HSR layout Division,
24th Main, 17th Cross,
HSR Layout ,2nd sector,
Bangalore.560 102
Date:

8 JAN 2020

To,

M/S Alekhya property Development, Pvt Ltd,
Sy No. 64/1,64/2,64/3,64/4 Kaikondarahalli Village,
Varthur (Ho), Bengaluru.

Sir,

Sub: Issue of NOC to the proposed Residential apartment purpose to an extent of 490KVA in favour of M/S Alekhya property development, Pvt Ltd, Sy No. 64/1,64/2,64/3,64/4 Kaikondarahalli Village, Varthur (Ho), Bengaluru.

Ref: Letter No. AEE/S11/AET/19-20/2499 dtd 08.01.2020.

With reference to the above, 'No Objection Certificate' from HSR layout Division, BESCOM is hereby issued for the proposed Residential apartment Purpose to an extent of 490KVA in favour of M/S Alekhya property development, Pvt Ltd, Sy No. 64/1,64/2,64/3,64/4 Kaikondarahalli Village, Varthur (Ho), Bengaluru.

Subject to the following conditions:

1. Power supply to your proposed M.S. Building will be arranged by providing new 11KV feeder from 66/11KV RMZ Eco World Adarsh Muss by Laying 3x400Sqmm XLPE UG cable to a distance of 0.7Kms & 1no. 3way Das compatible RMU proposed inside the applicant premises under self execution.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **Self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
3. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at your cost. This NOC does not apply to the premises where EHT lines are passing through your premises for which NOC is to be obtained from the concerned authorities.
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said building at the above address, all rules as per conditions of supply of Electricity of Distribution Licensees in the state of Karnataka dtd 17.6.2006 shall be observed.
6. Power supply shall be arranged to the said buildings based on the provisions of regulations of BESCOM as applicable at that time.

7. This "NOC" is issued only for the purpose of obtaining sanction for MS building plan from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
8. The approximate load requirement of the above proposed Residential apartment purpose is 490KVA.
9. This NOC is valid for a period of Two years from the date of issue.

Yours faithfully,

(Shivanna.K)

Executive Engineer Elecl.,
HSR Layout Division., Bengaluru.

Copy:

1. The Asst. Executive Engineer (Ele), S11 sub division, BESCOM, Bangalore for information
2. O/C to AE-1, / MF

ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು (ವಿ)
ವಾ. ಸಾ ಮತ್ತು ಪಾ. ಹೆಚ್.ಎಸ್.ಆರ್. ಬಡಾವಣೆ ವಿಭಾಗ
ಬೆ.ವಿ.ಕಂ., ಬೆಂಗಳೂರು-560 102