

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No.: EEE/MLMD/AEE(O)/AE-2 4933

Dated: 15 JAN 2013

To,

Sri.G.S.Vishwas & G.S.Vinay (Owner)
Sri.Umang Badjatya (GPA Holder)
M/s. Kumar properties Pvt., Ltd.,
Natakarathna Gubbiveeranna road,
Bangalore

Sir,

Sub: Issue of NOC for arranging power supply to an extent of 384.12 KVA /326.50KW the proposed Residential purpose in favour of Sri.G.S.Vishwas & G.S.Vinay (Owner) Sri.Umang Badjatya (GPA Holder) M/s. Kumar properties Pvt., Ltd.,Natakarathna Gubbiveeranna road, Bangalore

Ref: 1. AEE/C2/AET/1905 dt.03.01.2013.
2. Consumer ltr.No.NIL dt. 03.01.2013

With reference to the above, NOC is hereby issued to the proposed residential purpose of Sri.G.S.Vishwas & G.S.Vinay (Owner) Sri.Umang Badjatya (GPA Holder) M/s. Kumar properties Pvt., Ltd.,Natakarathna Gubbiveeranna road, Bangalore in C2 sub division to an extent of 384.12 KVA /326.50KW subject to the following conditions:-


1. Power supply will be arranged as regular source from feeder F3 A Station MUSS & alternate source from IISC MUSS F3 feeder.
2. You have to carry out all necessary works on self execution basis as per the estimate to be prepared by BESCOM under self execution and necessary supervision charges on 10% of the total cost of the estimate has to be paid.
3. While applying for power supply to the said premises, all rules as per KERC Electricity Supply and distribution code shall be observed.

Office of The Executive Engineer (El), Malleshwaram Division,
BESCOM, 13th Cross, Margosa Road, Malleshwaram, Bangalore-3.
Ph.23349994 Email ID:eeedbescm@gmail.com

4. You have to obtain approval from Electrical Inspectorate Govt. of Karnataka and same should be furnished while availing power supply if necessary.
5. This NOC is issued only for the purpose of obtaining sanction of plan from BDA/BBMP/competent authorities and is not a commitment for power sanction, from BESCOM. The power will be sanctioned subject to feasibility and as per rules prevailing at that time.
6. The existing LT installation if any have to be surrendered before taking up the infrastructure work of the proposed residential building.
7. If any KPTCL/BESCOM lines are passing through the above premises the same shall be shifted at your cost.
8. BESCOM shall not be held responsible for any liability arising from the issue of NOC.
9. This NOC shall be produced at the time of availing permanent power supply to the above building.
10. The validity of this NOC is for a period of Two years only.

Service charges of Rs.5,000/- has been paid vide Rt. No.624529220526 dt. 02.01.2012.

Yours faithfully



(M.R. Ramesh)

Executive Engineer (El)
Malleshwaram Division

Copy to :

1. The Assistant Executive Engineer (Ele.), Malleshwaram Division, BESCOM, Bangalore.
2. AE-2

Office of The Executive Engineer (El), Malleshwaram Division,
BESCOM, 13th Cross, Margosa Road, Malleshwaram, Bangalore-3.
Ph.23349994 Email ID:eeedbescm@gmail.com