



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No: CEE/BMAZ/SEE(O)/AEE-1/F-115/14-15/ 4833-37
Encl:

Office of
The Chief Engineer Ele.,
(C,O&M), BMAZ, No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

Date: 24-09-2015

To,
M/s ETA Star Info Park and other,
GPA, M/s. Relationship Properties Pvt Ltd.,
No.1/1, Binnypet, Hosakere Road,
Bangaluru.

Sir,

Sub:- NOC for arranging Power supply to an extent of **16.5 MVA for the proposed MSB (residential) in favour of M/s ETA Star Info Park and others GPA M/s. Relationship Properties Pvt Ltd.,** at No.1/1, Binnypet, Hosakere Road, Bangaluru.

Ref:- 1. Ltr.No.CEE(P&C)/SEE(Plg)/EEE(Plg)/KCO-95/F-46611/2012-13/R-51(59)/22.03.2013.
2. Note approved by Hon'ble DT BESCOM dated: 19.09.2015.
3. Ltr. No. CGM(OP)/DGM-3/AGM-1/BC-18/F-533(81)/15-16/8000/19.09.2015.

Approval is hereby accorded for renewal of NOC as per the approval issued vide letter cited under ref (3) for arranging power supply to an extent of 16.5 MVA for the proposed MSB (residential) in favour of M/s. ETA Star Info Park and others, GPA M/s. Relationship Properties Pvt Ltd., at No.1/1, Binnypet, Hosakere Road, Bangalore from 220 KV, 'A' Station subject to following conditions:-

- You shall construct 66/11 KV sub-station in the land already handed over to KPTCL under self-execution with appropriate capacity transformers and with provision for construction of 66 KV terminal bay for KPTCL future use.
- You shall construct 66 KV line using 66 KV 1000 Sq.mm UG cable from 220/66 KV 'A' station to the proposed 66/11 KV sub-station at your premises for a distance of about 4 KMs under self-execution.
- You shall give an under taking that, you shall maintain the 66 KV 1000 Sq.mm UG cable laid by yourself at your own cost for the life time.
- You shall construct 66 KV terminal bay and carryout all the necessary modification work at 220/66 KV 'A' Station under self-execution.
- 11 KV system will be as per BESCOM standard practices.
- The validity of NOC is for Two years from the date of this letter and the power supply position will be reviewed at the time of issuing regular power supply sanction only after the settlement of the dispute between the consumer and the Binny Mill Maaji Karmikara Kshemabhivruddi Sangha (R).
- BESCOM will not be held responsible for any liability arising for the issue of NOC.
- If any lines of KPTCL / BESCOM are passing in the your premises, these shall be got shifted by the yourself under Self-Execution as per KPTCL / BESCOM norms.

- i) This NOC is issued only for the purpose of obtaining sanction for MS building plan from BDA/BBMP/Competent authorities and it is not a commitment for power sanction to any constructed building in the premises from BESCOM. However, power supply will be sanctioned against the application on the basis of feasibility.
- j) In future, if you apply for power supply to the buildings constructed in the above premises, then you have to follow the prevailing KERC rules and BESCOM norms.

Yours faithfully,


Chief Engineer (Elec.)
(C,O&M), BMAZ, BESCOM.

Copy to:

1. The Superintending Engineer Ele., (C,O&M), Bangalore Circle (East), BESCOM, Bangalore for information.
2. The Executive Engineer, Elec., (C,O&M), **VidhanaSoudha** Division, BESCOM along with file.
3. The Asst. Executive Engineer, Elec., **W-3 Sub-Division**, BESCOM.
4. AEE-1/ MF/F-115