



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: EE/HSRD/JE-1/ 2173
Encl:

Office Of
Executive Engineer Elec(C,O&M)
HSR Layout Division, BESCOM,
17th cross, 24th main, HSR 2nd sector,
Bangalore-560102.

Date: 28/6/12

Sri.Rajendra Patil & Others,
JDA M/s Sterling Developers Private Ltd,
Sy.No:10,55,7/2,8/2,9/10,9/11,9/12,9/13,9/14,9/15 & 9/16,
Koramangala Sarjapura Road,
Near Ayappaswamy temple, Agara Village,
Begur Hobli,Bangalore.

Sir,

Sub:- Issue of NOC to the proposed **Residential Building** for arranging power supply to an extent of **755KVA (640KW)** in favour of Sri.Rajendra Patil & Others, JDA M/s Sterling Developers Private Ltd, Sy.No:10,55,7/2,8/2,9/10,9/11,9/12,9/13,9/14,9/15 & 9/16,Koramangala Sarjapura Road, Near Ayappaswamy temple, Agara Village, Begur Hobli, Bangalore. of S-11 Sub-division.

Ref:- 1) AEE(E)/S11/AE(T)/1160 dt:21.06.12 of the Assistant Executive Engineer Ele, HSR Layout, S-11 Sub-Division, BESCOM,Bangalore.

2) Applicant ltr.Dt:20.06.12

With reference to the above, '**No Objection Certificate**' from **EE, BESCOM** is hereby issued for issue of NOC to the proposed **Residential Building** for arranging power supply to an extent of **755KVA (640KW)** in favour of Sri.Rajendra Patil & Others, JDA M/s Sterling Developers Private Ltd, Sy.No:10,55,7/2,8/2,9/10,9/11,9/12,9/13,9/14,9/15 & 16,Koramangala Sarjapura Road, Near Ayappaswamy temple, Agara Village, Begur Hobli, Bangalore of S-11 Sub-division Subject to the following conditions:

1. Power supply to be arranged from Regular source from 66/11KV **Shobha MUSS.**

Regular Source: -

- a) It is proposed to evacuate new feeder from Shobha MUSS by laying 3X400Sqmm UG Cable to a distance of 2.4KM by providing 3 nos. of Intermediate OD's.
- b) It is proposed to provide 1 no of 2OD+1VL RMU.
- c) It is proposed to install 2X500KVA DTC under self-execution.

Alternate Source: -

- a) Alternate source is proposed from F8 feeder of HSR MUSS by using 3X400Sqmm to a distance of 0.5KM. If the requested load is more than the load mentioned in the applicant's premises, separate feeder should be provided from HSR MUSS.

2. BESCOM will not be held responsible for any liability arising from the issue of NOC.
3. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at the applicant cost.
4. If any installations existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said Residential apartment at the above address all rules as per KERC Electricity supply and distribution code shall be observed.
6. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
7. The necessary infrastructure for arranging power supply to the said premises shall be developed under self execution by the applicant.
8. This 'NOC' is issued only for the purpose of obtaining sanction for the Residential Apartment plan from BDA/BBMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
9. The necessary infrastructure for arranging power supply to the said premises shall be developed under self execution through class-I LEC.
10. For Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat.
11. As per the above, if there is no sufficient space to provide solar water heaters block of Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat for total no. of flats on the top of the blocks.
12. Validity of this NOC is for 2(Two) years only from the date of this letter. (28/6/2012)

Yours faithfully


Executive Engineer (Ele)
C, O&M, HSR Layout Division,
BESCOM, Bangalore.



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

MC

8781/939

: 6995

Payment Date : 20/04/2012 2:29:40 PM AWP(1.4)

City Counter : 1, REGULAR COUNTER

Payment towards : OTHERS

Payee Name : STERLING DEVELOPERS P(NOC

Letter No

Folio No

Amt Paid : Rs. 5000

RUPEES FIVE THOUSAND ONLY

ಕವರಿ
ಮೊದಲು

Mainu Enterprises

THANK YOU



Approved for
NOC - on - 20/04/12
Hon. Shashi Electricals
For Ltr.