



**GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)**

Lr. No

Date : 13/09/2022

Ack No : EI000110460790

O/o Chief Electrical Inspectorate to Govt.,
Nirman Bhavan, 2nd Floor, P.B. No5148 ,
Dr . Rajkumar Road, Rajajinagar, Bangalore-560010
Phone No :080-23371693

GSC No :

To

G S VISHWAS AND OTHERS REP BY GPA KUMAR
PROPERTIES PVT LTD REP BY UMANG BADJATYA
No 214/215(Old No 19/20),, S C Road, Sheshadripuram
Bangalore, BENGALURU(District), BENGALURU NORTH(Taluk)
Karnataka, India-560020

Sir,

Sub : Approval of electrical installation pertaining to Residential LTMS Building having BF+GF+9UFs+Part of 10th Floor only fed from 1x500kVA, 11kV/433V Transformer **G S VISHWAS AND OTHERS REP BY GPA KUMAR PROPERTIES PVT LTD REP BY UMANG BADJATYA** No 214/215, Old N o 19/20, S C Road, Sheshadripuram, Sheshadripuram, Bangalore, BANGALORE EAST(District), BANGALORE EAST(IRA)(Taluk) - 560020

Drawing Ref No : EI000110455311

Ref : 1. T.O Ltr No: CEIG/ACEI/EI-1/AEI-1/BN-137/10024/22-23 Dated: 01.092022 approving of installation drawings EI000110455311

2. Work Completion Report Submitted through online portal vide Ack No: EI000110460790

With reference to the above, approval is hereby granted for energizing the electrical installation at [**G S VISHWAS AND OTHERS REP BY GPA KUMAR PROPERTIES PVT LTD REP BY UMANG BADJATYA** with **No 214/215, Old N o 19/20, S C Road, Sheshadripuram, Sheshadripuram, Bangalore, BANGALORE EAST, BANGALORE EAST(IRA) - 560020**] under Regulation No. [43,36] of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2010 as per details enclosed.

This approval is strictly subject to your full compliance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2010 (as amended to date) in every respect.

Note :

.

Conditions :

1. As per Regulation No: 46(5) and 46(6) required records shall be maintained.
2. As per Regulation No: 46(7) the installation shall be maintained and operated in a condition free from danger.
3. As per Regulation No: 3 designated person(s) shall operate and carryout the work on electrical lines and apparatus.

Inspection fee of **Rs. 11,450/- (IN WORDS) Eleven Thousand Four Hundred Fifty** only paid vide K2 Challan Ref. No: **EL0922004300000351** dated **01/09/2022**

Details of Equipments :

I) 1x500kVA, 11kV/433V Transformer

1. HT Cable: a) 1Rx3Cx95sqmm 11kV XLPE UG cable from existing tapping point to proposed 3 Way RMU of length 0.158 Kms
b) 1Rx3Cx95Sqmm 11kV XLPE UG cable from existing Shivashankar RMU to proposed 3 way RMU of length 0.04 Kms
c) 1Rx3Cx95sqmm 11kv XLPE UG cable from 3 Way RMU to proposed Transformer of length 0.01 Kms
2. HT Switchgear : Make: Schneider Electric, 12kV, 630A, 21kA/for 3 Sec
(2 OD + 1VL) RMU, Sl. No: FBX 220085
3. Transformer : Make: Vijay Electric Co, 1x500kVA, 11kV/433V, 26.24/666.66A, Sl. No: VEC/500/L3005-01
4. LT Cable : 2Rx3.5Cx240Sqmm LT UG cable from Transformer to LT Kiosk of length 0.01 Kms
5. LT Switchgear : MCCB, 800A, Make: Schneider (01 No)

II) M.S. Building Installation Details

1. No. of floors : BF+GF+9UFs+part of 10th floor only
2. Sanctioned Load : 399kW only
3. LT Cable : 2Rx3.5Cx240Sqmm UG cable of length 0.240Kms
4. LT Switchgear : MCCB, 800A, Make: Schneider (01 No)

Conditions:

- 1.This approval is strictly restricted the sanctioned floors only.
- 2.Any type litigations by private / public or any other authorities, Responsibility lies with applicant only.
- 3.Comply the norms of any other licensing /Approving authorities.
- 4.The approval accorded is as per safety provision of CEA regulations 2010, it shall not be considered for any type of bill payment.
- 5.The erection permission to install the lifts and licence to run the lifts shall be obtained from the competent authority of this Department.
- 6.Drawing approval shall be obtained for the D.G. sets before installation and commissioning approval is to be obtained for running the D.G. set.
- 7.Any addition/alteration to the installation shall be got approved from this department



Digitally Signed by : T N APPACHU
Chief Electrical
Inspector to Government[INCHARGE]
Bangalore
Signed Date :13/09/2022

Note: This is a Digitally Signed Certificate and Does not require manual signature.

Please, Verify authenticity of this certificate by visiting www.ksei.gov.in and entering certificate number in Third party verification.