

to terrace level which are as per the details shown on the enclosed plans, signed in token of approval, subject to satisfactory compliance of Fire Safety:

2. Earlier N.O.C. of Fire Protection & Firefighting requirements issued by this department vide no. - FB/HR/CITY/744, dated 30/04/2010 & FB/HR/CITY/291, dated 19/11/2012 for the proposed construction of High-rise Residential building shall be strictly adhere to along with modified following stipulated amendments & additional Fire Protection & Firefighting requirements:

3. AMENDMENTS TO N.O.C. U/NO. - FB/HR/CITY/291, dated 19/11/2012:

A]- Amendment to the requirement Sr. No. 4) STAIRCASE:

- i) Externally located staircases adequately ventilated to outside air.
- ii) No combustible material shall be kept or stored in staircase/passage.

Terrace Staircase;

The staircase door shall be provided in the following manner;

- i) The top half portion of the doors shall be provided with wind louvers.
- ii) The latch- lock shall be installed from the terrace side at the height of not more than 1mtrs.
- iii) The glass front of 6 inch diameter with the breakable glass shall be provided just above the latch lock, so as to open the latch in case of an emergency by breaking the glass.
- iv) The door shall either be fitted with magnetic lock connected to console & detection system or shall be synchronized with fire detection and alarm system.

B]- Amendment to the requirement Sr. No. 8) ESCAPE ROUTE FROM FLAT TO STAIRCASE (CORRIDOR/LIFT LOBBY):

- i) The common corridor/lift lobby at each floor level shall be kept free from obstructions at all times.
- ii) Portable lights/insta lights shall be provided at strategic locations in the staircase and lift lobby.

C]- Amendment to the requirement Sr. No. 9) ESCAPE ROUTE (STAIRCASE AND CORRIDOR) LIGHTINGS:

- i) The staircase and corridor lighting shall be on separate circuits and shall be independently connected so that they could be operated by one switch installation on the ground floor easily accessible to firefighting staff at any time irrespective of the position of the individual control of the light points, if any.
- ii) Staircase and corridor lighting shall also be connected to alternate supply.
- iii) Double throw switches should be installed to ensure that lighting in the staircase and the corridor do not get connected to two sources of supply simultaneously. A double throw switch shall be installed in the Service room to terminate the stand - by - supply.

D]- Amendment to the requirement Sr. No. 10)- FLATS/SHOPS ENTRANCE, KITCHEN DOORS & EXIT/ENTRANCE STAIRCASE:

- i) The fire resistance rating for staircase F.R.D., Lift lobby / protected lobby & the lift doors as per N.B.C. provisions.