



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

No: EEE/CDP/AEE (O)/AE (T) 4718-19

Office of the
Executive Engineer (Ele)
C, O & M Division, Chandapura
Date:

25 SEP 2013

To,
M/s LGCL Urban Homes India LLP
Sy. No. 11, 12, 13/1 & 22,
Choodasandra Village,
Anekal Taluk.

Sir,

Subj:- Issue of NOC to your proposed residential layout of M/s LGCL Urban Homes (India) LLP, Sy. 11, 12, 13/1, & 22 at Choodasandra Village, Chandapura Sub-Division, Anekal taluk

Ref:1) AEE/CDP/AE(T)/1525 Dated 11.09.13

With reference to the above, "No Objection Certificate" from BESCOM side is hereby issued for your proposed residential layout in the name of M/s LGCL Urban Homes (India) LLP, Sy. No. 11, 12, 13/1 & 22, Choodasandra Village, Chandapura Sub-Division, Anekal taluk.

1. The power supply to your proposed residential layout will be arranged from existing F-16 HSR MUSS by extending the 11 KV Line to distance of 175 Mtrs under self Execution.
2. The Existing Primary/secondary line which is passing through your premises is to be shifted at your own cost before commencement of the work. Sufficient horizontal clearance (Corridor) shall be maintained from the existing EHT lines, and there shall not be any construction underneath the existing EHT lines if any.
3. While applying for power supply to your proposed residential layout, all formalities as per KERC Electricity Supply and Distribution Code 2004 shall be observed.
4. Power supply will be arranged to the proposed residential layout that may come up in the above premises as per provision or regulations in BESCOM. Prevailing at that time.
5. If any existing installation should be surrendered by clearing all the arrears, before taking up infrastructure work in the premises.
6. NOC is issued only for the purpose of obtaining sanction for the plan of proposed layout from the BDA/BMRDA/CMC/Competent authority and it is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to the feasibility prevailing at that time.
7. The approximate load requirement for the above proposed residential layout is 804 KWs
8. The consumer has paid necessary Service Charges Rs. 5650.00 RI. No. 9716
Dated 11.09.13
9. BESCOM will not be held responsible for any liability arising from the issue of NOC.
10. This NOC is valid for a period of two (2) years from the date of issue of this letter.

Yours faithfully,

(H.C Sreeramgowda)
Executive Engineer (Ele),
C, O&M Division, Chandapura