

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka undertaking)

No: EE/KMLD/AEE(O)/16-17/01 - 02
Ph: 080-25631801
Fax: 080-25631801
E-Mail : eeKoramangala@bescom.co.in
Encl:

Office of the,
Executive Engineer (Elec.),
(C,O&M), Koramangala Division,
No.6, 7th Main, 80ft Road,
3rd Block, Koramangala,
Bangalore-560 034.

Date:

To
M/s. LGCL urban Homes (India) LLP,
United Towers project, K.No.234/134/134,
Kadubisanahalli, Bellandur Village Marathahalli,
Ward No.150, Bengaluru.

Sir/Madam,

Sub: Issue of NOC for arranging power supply to an extent of 321 KW in favour of M/s. LGCL urban Homes (India) LLP, United Towers project, K.No.234/134/134, Kadubisanahalli, Bellandur Village Marathahalli, Ward No.150, Bengaluru in Marthahalli O&M Unit, S-7 Sub Division, Bengaluru.

Ref: Ltr No: AEE/S7/AET/16-17/4700. Dtd: 15.03.17

As per the field report furnished by the Assistant Executive Engineer (Ele) S7 Sub Division, the **No Objection Certificate** is hereby issued in your favour at K.No.234/134/134, Kadubisanahalli, Bellandur Village Marathahalli, Ward No.150, Bengaluru in Marthahalli O&M Unit, S-7 Sub Division, Bengaluru, subject to the following conditions:

1. By extension of F-10 feeder from Bank-2 of Sobha MUSS by laying of 3CX240 Sqmm XLPE UG Cable to a distance of 0.4 Kms by providing (2OD+1VL) DAS RMU as regular source under self-execution scheme.
2. Execution of the works mentioned above have to be executed from your end at your own cost on self-execution basis by paying 10% supervision charges & 15% service tax on supervision charges on total cost of the estimate prepared by BESCOM.
3. Payment of augmentation charges for availing LT power supply and observance of other formalities mentioned in conditions of Supply of Electricity Distribution license shall be followed.
4. While applying for power supply to the said building at the above address all conditions as per KERC Electricity Supply & Distribution Code shall be observed.

- a. Any KPTCL./BESCOM lines passing in your premises shall be shifted at your own cost under self-execution scheme and if any installation existing in the premises shall be surrendered as per Corporate rules and formalities.
6. In future, if the requested load exceeds 7500 kVA, you have to provide prescribed space to establish a 66/11kV MUSS at free of cost to KPTCL.
7. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
8. This NOC is issued only for the purpose of obtaining sanction plan for the building from competent authorities and not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied, subject to feasibility at that time.
9. The approximate load requirement of the above MS building is 321 KW.

The Validity of this NOC is for a period of Two years only from the date of issue.

Yours Faithfully



(Channakeshava.H.D)
Executive Engineer (Elec),
Koramangala Division,
BESCOM, Bangalore.

Copy to:

- 1) Assistant Executive Engineer Ele, C, O&M, S-7 Sub-Division, Bangalore.
- 2) MF/OC.