



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: EE/HSRD/JE-1/ 9659-60
Encl:

Office Of
Executive Engineer Elec(C,O&M)
HSR Layout Division, BESCOM,
17th cross, 24th main, HSR 2nd sector,
Bangalore-560102.

Date: 4 MAR 2013

Sri.Jangama Reddy & Others,
GPA M/s LGCL Properties Private limited,
rep by Sri.Girish Puravankar,
Sy.No:36/2, 36/3, 36/4 & 40/2,
Naganathapura Village,
Bangalore.

Sir,

Sub:- Issue of NOC to the proposed **Residential Building** for arranging power supply to an extent of **495KW(584KVA)** in favour of Sri.Jangama Reddy & Others, GPA M/s LGCL Properties Private limited, rep by Sri.Girish Puravankar, Sy.No:36/2, 36/3, 36/4 & 40/2, Naganathapura Village, Bangalore.

Ref:- 1) AEE(E)/S11/AE(T)/5952 dt: 26.02.13 of the Assistant Executive Engineer Ele, HSR Layout, S-8 Sub-Division, BESCOM, Bangalore.

2) Applicant ltr.Dt: 11.02.2013.

With reference to the above, **'No Objection Certificate' from EE, BESCOM** is hereby issued for issue of NOC to the proposed **Residential Building** for arranging power supply to an extent of **495KW (584KVA)** in favour of Sri.Jangama Reddy & Others, GPA M/s LGCL Properties Private limited, rep by Sri.Girish Puravankar, Sy.No:36/2, 36/3, 36/4 & 40/2, Naganathapura Village, Bangalore. of S-8 Sub-division subject to the following conditions:


1. Power supply to be arranged from Regular source from 66/11KV **Naganthapura MUSS.**

Regular Source: -

- a) It is proposed to lay 3X400Sqmm XLPE HT UG cable from existing F11 feeder of Naganathapura MUSS by interposing RMU at tapping point.
- b) It is proposed to provide 2OD+3VL RMU inside applicant premises under self execution.
- c) It is proposed to install 3X250KVA DTC's inside applicant premises.
- d) If the requested load exceeds 1000KVA, then the applicant has to lay new 11KV feeder from Naganathapura MUSS with an alternate source from other station.

2. BESCOM will not be held responsible for any liability arising from the issue of NOC.
3. If any KPTCL/BESCOM lines are passing through the applicant premises these shall be shifted at the applicant cost.
4. If any installations existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said Residential apartment at the above address all rules as per KERC Electricity supply and distribution code shall be observed.
6. Power supply will be arranged to the various buildings that may come up at the above address as per the provisions of regulations of BESCOM at that time.
7. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution by the applicant.
8. This 'NOC' is issued only for the purpose of obtaining sanction for the Residential Apartment plan from BDA/BBMP/BMIC/Competent authorities and is not a commitment for power sanction from BESCOM. Power supply will be sanctioned when applied for, subject to feasibility at that time.
9. The necessary infrastructure for arranging power supply to the said premises shall be developed under self-execution through class-I LEC.
10. For Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat.
11. As per the above, if there is no sufficient space to provide solar water heaters block of Residential Apartments solar heaters should be provided with a capacity of 100 liters either for individual flat or bulk solar water heaters to be provided with suitable capacity which may be arrived by calculating 100 liters/flat for total no. of flats on the top of the blocks.
12. Validity of this NOC is for 2(Two) years only from the date of this letter.

Yours faithfully

 4/3/13
(A.N. Jayaraj)

**Executive Engineer (Ele)
C, O&M, HSR Layout Division
BESCOM, Bangalore.**