



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/AEE-3/**NOC-21/14-15/**
Encl: **13110-12**
Email: sessouthcircle.work@gmail.com
Ph: 22230636, Fax: 22118861

Superintending Engineer, C, O&M, Bangalore
South Circle, BESCOM No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

To

M/s. DNR Corporation Pvt Ltd,
Rept by Sri. Vipul Kumat,
Sy No. 33, K. No. 833/33,
Ibbaluru Village, Begur Hobli,
Bangalore.

5 JAN 2015

"REVISED"

Sir,

Sub:- Issue of NOC for arranging power supply to an extent of **1300KVA** to the proposed **Residential Building** in favour of M/s. DNR Corporation Pvt Ltd., Rept by Sri. Vipul Kumat, Sy No. 33, K. No. 833/33, Ibbaluru Village, Begur Hobli, Bangalore.

Ref:- Ltr No. EE(E)/HSRD/AEE(O)/JE-1/6208 dt: 26.12.2014.

With reference to the above, '**No Objection Certificate**' is hereby issued for arranging power supply to the proposed Residential Building to an extent of **1300KVA** at Sy No. 33, K. No. 833/33, Ibbaluru Village, Begur Hobli, Bangalore, subject to the following conditions: -

1. Power supply to your proposed total blocks - **01 Block with 2BF+GF+12UF's** for Residential Building in the total land area - **3 Acre 19 Guntas** will be arranged with the following arrangements.

Proposals:

Regular Source:

- a. To run new feeder from Sobha MUSS by laying 3x400Sq.mm UG cable to the applicant premises to a distance of 1.6km by providing one No. of intermediate OD's & a separate 11KV breaker in the MUSS.
- b. To provide 5way RMU (2OD+3VL) & 6x250KVA Transformers inside the premises.

Alternate Source:

- c. To run new feeder from Sulikunte MUSS to applicant premises by lay 3x400Sq.mm UG cable to a distance of 7.0km by providing 6Nos. of intermediate OD's.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. **This NOC does not apply to the premises where EHT lines are passing through the premises for which a separate NOC is to be obtained from the concerned KPTCL authorities.**
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said **Residential Building** /various buildings at the above address, all prevailing rules of KERC at that time and Conditions of Supply shall be observed.
6. Power supply shall be arranged to the said **Residential Building** based on the provisions of regulations of BESOCM as applicable at that time.
7. This "NOC" is issued only for the purpose of obtaining sanction plan for **Residential Building** from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
8. The approximate load requirement of the above **Residential Building** is 1300KVA.
18. If the requisitioned load is 4000KVA to 7500KVA, land measuring 50mtr x 60mtr shall be handed over to KPTCL / BESCOM at free of cost for establishing 66/11KV sub station.
9. If the requisitioned load is more than 7500KVA, the applicant has to establish 66/11KV sub station inside the premises under self execution.
10. If the requisitioned load exceeds 2000KVA, provision shall be made for evacuating alternate source.
11. This **NOC** is valid for a period of **Two year** from the date of issue.

Yours faithfully,

(Mohan Kalluraya N)

Superintending Engineer (EL.),
Bangalore Circle (South), BESCOM,
Bangalore