



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No.: SEE/BCS/EE(O)/AEE-2/NOC-05/13-14/

Encl:

Email: southcircle.work@gmail.com

Ph: 22230636, Fax: 22118861

Superintending Engineer, C, O&M, Bangalore
South Circle, BESCOM No. 14/3, 3rd Floor,
Maharshi Aravinda Bhavan, Nrupathunga
Road, Bangalore-560 001.

4/58-60

To

M/s. Ferns Builders & Developers,
Sy No. 71, 89, 90, 91/1, 91/2, 94/1 & 94/3,
Haralur Village, Varthur Hobli, Bangalore.

11 3 JUN 2013

Sir,

Sub:- Issue of NOC for arranging power supply to an extent of **1936KVA** to the proposed **Residential Apartment** in favour of M/s. Ferns Builders & Developers, Sy No. 71, 89, 90, 91/1, 91/2, 94/1 & 94/3, Haralur Village, Varthur Hobli, Bangalore.

Ref:- Ltr No. EE(E)/HSRD/AEE(O)/JE-1/1080 dt: 22.05.2013.

With reference to the above, 'No Objection Certificate' from BCS, BESCOM is hereby issued for arranging power supply to the proposed **Residential Apartment** to an extent of **1936KVA** at **Sy No. 71, 89, 90, 91/1, 91/2, 94/1 & 94/3, Haralur Village, Varthur Hobli, Bangalore**, subject to the following conditions:

1. Power supply to your proposed **Block1 (GF+14UF's), Block2 (SF+FF+15UF's), Block3 (GF+3UF's)** Residential Apartment will be arranged with the following arrangements.

Regular Source:

- a. To lay 3x400Sq.mm UG cable from Shobha MUSS by providing intermediate OD's.
- b. To install 2OD+1VL RMU inside the applicant's premises under self execution.

Alternate Source:

- c. To lay 3x400Sq.mm UG cable to a distance of about 0.6km existing F-5 feeder of HSR MUSS by providing spun pole with GOS. If the requested load is more than the load mentined in the applicants premises separate feeder should be provided from HSR MUSS.
2. You have to develop the infrastructure including the cost of 11KV lines etc., as mentioned above on **self execution** basis through a Government Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.

..2)

3. If any KPTCL/BESCOM lines are passing through the applicant's premises these shall be shifted at your cost. **This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned KPTCL authorities.**
4. If any installation existing, the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
5. While applying for power supply to the said **Residential Apartment**/various buildings at the above address, all prevailing rules of KERC at that time and Conditions of Supply shall be observed.
6. Power supply shall be arranged to the said **Residential Apartment** based on the provisions of regulations of BESOCM as applicable at that time.
7. This "NOC" is issued only for the purpose of obtaining sanction plan for **Residential Apartment** from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. **Power supply will be sanctioned when applied for, subject to feasibility at that time.**
8. The approximate load requirement of the above **Residential Apartment** is **1936KVA 11KV.**
9. This NOC is valid for a period of **Two year** from the date of issue.
10. This NOC is subjected to outcome of the appeal case pending before the appellate authority.

Yours faithfully,



(D. Nagarjuna)
Superintending Engineer (El.),
Bangalore Circle (South), BESCOM,
Bangalore