



Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking)

No: CEE/BMAZ-N/SEE(O)/AE-1/23-24/

Encl:

Ph.No.

Email:ceenz@bescom.co.in

cebmaznorth@gmail.com

2958-61

Office of the

The Chief Engineer (Ele), (C,O & M)

BMAZ-NORTH, BESCOM,

#8,Nandi Durga Road, Benson Town

Bangalore-560046

Date: 4 NOV 2023

To,

Smt.P.Kalavathi and others &
HV Ventures Projects Pvt Ltd,
Sy no. 186/4, 186/1, 187/2, 187/1
Graphite India Main Road,
Hoody Village, Bengaluru.

Sir,

Sub: Arranging power supply to an extent of 1470kWs in favour of Smt.P.Kalavathi, Sri. Y.R. Sunil, Sri. Y.R. Anil, YV Prasad, HV Kalpana & HV Ventures Projects Pvt Ltd, Sy no. 186/4, 186/1, 187/2, 187/1 Graphite India Main Road, Hoody Village, Bengaluru in E12 Sub division of Whitefield Division under self-execution-reg

Ref: 1. Letter no: SEE/BEC/EE(O)/AEE/23-24/6133-34 Dated: 20.10.2023 of SEE, BEC

With reference to the proposal cited under ref[1] regarding "Arranging power supply to an extent of 1470kWs in favour of Smt.P.Kalavathi, Sri. Y.R. Sunil, Sri. Y.R. Anil, YV Prasad, HV Kalpana & HV Ventures Projects Pvt Ltd, Sy no. 186/4, 186/1, 187/2, 187/1 Graphite India Main Road, Hoody Village, Bengaluru in E12 Sub division of Whitefield Division under self-execution". Approval is hereby accorded subject to the following conditions,

1. You shall arrange power supply on self-execution as mentioned below :

- Regular Source :** You shall tap the existing 11kV F-13 feeder of Hoody Sub-station by from existing 3x400sqmm UG cable and extend the line by providing 3x400 sq mm straight through joint using 3x400sqmm XLPE HTUG cable to a distance of 50Mtrs (25mtrsx2runs) by providing 3way DAS RMU inside the consumer premises under self-execution.
- Alternate Source:** You shall arrange alternate power supply by tapping existing 11kV F19 feeder of Shanthinikethan Sub station and extend 11kV line using 3x400sqmm XLPE HTUG cable to a distance of 50Mtrs (25mtrsx2runs) by providing 3way DAS RMU near to consumer premises under self-execution.

2. You shall provide 1 no of 5way DAS RMU, 2 nos of 3 way DAS RMU and 3x500KVA Oil type transformer.

3. You are requested to pay following charges by DD payable at the office of the Asst. Executive Engineer (Ele), C, O&M, BESCOM E12 Sub-division within 90days from the date of this intimation. (Note: Power sanction generated at RAPDRP portal is the final amount to be paid in case of any variation)

a. 2MMD - Rs. 12,41,000/-

Sl. no.	Tariff	Load in KW	Nos	Total Load in KW	Unit price	Extended price in Rs.
1	LT-2a	3	152	456	2550	3,87,600.00
2	LT-2a	4	126	504	3400	4,28,400.00
3	LT-2a	5	36	180	4250	1,53,000.00
4	LT-2a	40	1	40	34000	34,000.00
5	LT-2a	80	2	160	68000	1,36,000.00
6	LT-2a	120	1	120	102000	1,02,000.00
Total			318	1460	-	12,41,000.00

b. 2MMD for EV Charging station Rs. 9,100/-

Sl. no.	Tariff	Load in KW	Nos	Total Load in KW	Unit price	Extended price in Rs.
1	LT-6c	5	2	10	4550	9,100.00

c. Other Charges

1	Supervision Charges @ 10% of the est. cost	Rs. 9,29,933/-
	1a. CGST @ 9% of SC	Rs. 83,694/-
	1b. SGST @ 9% of SC	Rs. 83,694/-
2	RMU Testing Charges (3 No RMU)	Rs. 12,240/-
	2a. CGST 9% on testing Charges	Rs. 1102/-
	2b. SGST 9% on testing Charges	Rs. 1102/-
3	UG cable Charges	Rs. 20,000/-
	3a. CGST 9% on testing Charges	Rs. 1,800/-
	3b. SGST 9% on testing Charges	Rs. 1,800/-

- You shall complete the work as per sanctioned estimate under self-execution basis within 90 from the date of administrative approval.
- The materials used for executing the work shall be procured from the BESCOM approved vendors only
- 11 KV System shall be as per BESCOM standard practices.
- In future if the load exceeds 7500KVA, you have to establish 66/11KV sub-station at your premises under self-execution and avail power supply on 66KV basis as per KERC norms.
- As per KERC order no: KERC/CoS/DDD/1/2018-19/908, Bengaluru Dt: 22.10.2019 in the premises of proposed MS building applicant shall provide minimum 2 No's of charging points capable of charging Electric Vehicles i.e., four/ three/ two wheeler with adequate space in such building.
- The applicant shall abide by the rules/regulations left out and traced on the later dates.
- BESCOM is not responsible for any liabilities arising due to this intimation.
- You shall also abide to all the terms and conditions mentioned in power sanction intimation issued in RAPDRP portal for the above work.

12. You are requested to contact the Superintending Engineer (Ele.) ,Bangalore Circle (East), Executive Engineer (Ele),C,O &M, Indiranagar Division, BESCOM, Bangalore for further needful action in the matter.

Yours faithfully


Chief Engineer (Ele), (C, O & M)
BMAZ-NORTH, BESCOM,
Bangalore.

Copy to:

1. The Superintending Engineer(Ele), Bangalore East Circle, BESCOM, Banasawadi, Bangalore
2. Executive Engineer (Ele), C,O&M Whitefield division, BESCOM, Bangalore.
3. The Assistant Executive Engineer(Ele), C,O&M E12 sub- division, BESCOM, Bangalore to collect the payment and submit the payment certificate addressed to this office with a copy to EE, Whitefield division.
4. AE-1/MF.