

E]- Amendment to the requirement Sr. No. 11)- FIRE FIGHTING**REQUIREMENTS - E) AUTOMATIC SPRINKLER SYSTEM:-**

Automatic Sprinkler system shall be provided in the lift lobby & common corridor passage on each floor level and on 1st to 4th car parking floors level as per the standard laid down by T.A.C. & relevant I.S. specifications.

F] - Amendment to the requirement Sr. No. 11)- FIRE FIGHTING REQUIREMENTS - H) FIRE PUMP, BOOSTER PUMP, SPRINKLER PUMP, AND JOCKEY PUMP:

All the set of above said pumps shall be of surface mounted type or vertical turbine type.

G] - Amendment to the requirement Sr. No. 11)- FIRE FIGHTING REQUIREMENTS - I) EXTERNAL HYDRANT:

One no. of hydrant @ for every 30 Mtrs. of distance on ground around the building shall be provided within the confines of the site of the wet riser at location marked on the plan without hindering free maneuvering space for fire engines.

H]- Amendment to the requirement Sr. No. 11)- FIRE FIGHTING REQUIREMENTS - K) PORTABLE FIRE EXTINGUISHERS:

- i) One no. of Dry Chemical Powder (ABC type) fire extinguisher of 09Kgs. Capacity having I.S. certification mark and two bucket filled with dry clean sand shall be kept in electric meter room & in lift machine room as well as in car lift machine room.
- ii) Two nos. of Dry Chemical Powder (ABC type) fire extinguishers of 06Kgs. capacity having I.S.I certification mark shall be kept in entire building on every floor level including each podium car parking floors @ for every 100 Sq. Mtrs. of floor area.
- iii) One no. of Dry Chemical Powder (ABC type) fire extinguisher of 04Kgs. Capacity having I.S. certification mark shall be kept on each refuge area.

I]- Amendment to the requirement Sr. No. 15)- TRAINED FIREFIGHTING STAFF / SECURITY GUARDS:

- 1) The trained security / fire supervisor along with trained staff having basic knowledge of firefighting & fix fighting installation shall be provided / posted in the building. They will be responsible for the following :
- 2) Maintenance of all the first aid firefighting equipments, fixed installations and other firefighting equipments / appliance in good working condition at all times.
- 3) Imparting training to the occupants of the building in the use of firefighting equipment provided on the premises & kept them informed about the fire & other emergency evacuation procedures
- 4) To liaise with the City Fire Brigade on regular & continual basis.

J]- Amendment to the requirement Sr. No. 18)- REFUGE AREA:

Refuge area provided on part 8th & part 15th residential floor level shall be confirming to the earlier stipulated requirements.