



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka undertaking)

No: CEE/BMAZ/SEE(O)/AEE-3/F-116 6834 -37

Encl:

E-mail: cebmaz@bescom.co.in

Mobile no: 944904588

Phone No: 22113868

Fax: 080-22113839

Office Of

The Chief Engineer Ele.,

[C,O&M], BMAZ, No. 14/3, 3rd Floor,

Maharshi Aravinda Bhavan, Nrupatunga Road,

Bangalore-01.

Date:

14-12-2015

To,

M/s. Larsen & Toubro Construction

Equipment's Limited,

Byatarayanapura Village,

Yelahanka Hobli,

Bellary main road,,

Bengaluru .

Sir,

Sub: Issue of NOC for arranging power supply to an extent of 19000KVA in favour of M/s. Larsen & Toubro Construction Equipment's Limited for their proposed residential & Commercial MS Building at various survey numbers in Byatarayanapura Village, Yelahanka Hobli, Bellary main road, Bengaluru North taluk pertains to C-8 sub-division.


Ref: 1. Ltr.No.CGM(OP)/DGM(OP-3)/AGM(OP-1)/F-533(61)/15-16/11131 Dt: 02.12.2015.
2. Ltr.No. CEE(P&C)/KCO-95/F-34211/2015-16/R-67(44)/8608-11 Dt.: 19.11.2015

Approval is hereby accorded for the proposal for issue of NOC for arranging power supply to an extent of 19000KVA in favour of M/s. Larsen & Toubro Construction Equipment's Limited for their proposed residential & Commercial MS Building at various survey numbers in Byatarayanapura Village, Yelahanka Hobli, Bellary main road, Bengaluru North taluk from 220/66/11 KV Yelahanka DG Plant sub-station subject to following conditions:

- The applicant shall construct 66/11KV sub-station in their premises with suitable capacity transformer as per KPTCL specification at their own cost under self-execution basis, shall hand it over to KPTCL upon completion of work, and shall stand guarantee for a period of one year from the date of commission.
- The applicant shall construct 66KV line using 1000 Sq.mm UG cable from proposed 220/66/11 KV Yelahanka DG plant sub-station for a distance of 7.7 Kms under self-execution.
- The applicant shall construct 66KV terminal bay at proposed 220/66/11 KV Yelahanka DG plant sub-station duly purchasing the suitable adjacent land, for construction of 66 KV terminal bay at their own cost and carry out all the necessary modification works at the proposed 220/66/11KV Yelahanka DG plant sub-station under self-execution.
- 11 KV system shall be as per BESCOM standard practices.
- The validity of NOC is for two years from the date of this approval letter and the connectivity will be reviewed at the time of sanctioning regular connectivity.
- Connectivity for arranging power supply is feasible only after commissioning of proposed 220/66/11 KV Yelahanka DG Plant sub-station.
- BESCOM is not responsible for any disputes arising from this NOC.

- h. This NOC is issued only for obtaining sanction of building plan from BDA/BBMP or related departments.
i. This approval is subject to ratification in the ensuing KPTCL, TCC meeting.

Yours faithfully,


Chief Engineer Ele.,
(C, O&M), BMAZ, BESCO.